

MASCARILLA FFP2 NR COLOR NEGRO y BLANCO

FICHA TÉCNICA Y

DOCUMENTACIÓN

FÁBRICA: TRN MODA TEKTIL VE TIC. LTD. STI.





MASCARILLA FILTRANTE FFP2 NR - TAMAÑO ADULTO

NOMBRE DEL PRODUCTO: MASCARILLA FFP2 NR ADULTO

DISTRIBUIDORES E IMPORTADORES:

INCA PRODUCT S.L. AGRUPACIÓN SALUD-DA GAYO INVERSIONES SL.

Ávila(España) Alcorcón (España)

FABRICANTE:

TRN MODA TEKSTIL SAN. Ve Tic. Ltd. Şti.

Dirección: Selahaddin Eyyubi Mah, 1538. Sk. No: 32/4, 34517 Esenyurt / İstanbul / Turkey

CERTIFICACIONES Y DOCUMENTACIÓN:

EU declaración de conformidad del fabricante.

Modelo de mascarilla: TRNMT-NRF M002

Marca: TRN MedTex

Certificado del Módulo B categoria III según directiva 2016/425 y EN

149:2001+A1:2009 : EN 149:2001+A1:2009

Laboratorio: MNA LABORATUVARLARI SAN. TIC. LTD. STI.

Código del notificador: 2841.

Código test: M-2021-00461, M-2021-00620

Fecha: 07.04.2021

Certificado del Módulo C2 ANEXO VIII según normativa 2016/425 y EN 149:2001+A1:2009 :

Laboratorio: MNA LABORATUVARLARI SAN. TIC. LTD. STI.

Código del notificador: 2841. Código test: 200-21-02-R01-01

Fecha: 08.04.2021

Enlace de verificación del notificador. Foto del marcado de la mascarilla.

Adjuntamos documentación





MASCARILLA FILTRANTE FFP2 NR - TAMAÑO ADULTO

FOTO MARCADO DE LA MASCARILLA

MÁSCARA MARCADA CON:

- Nombre de la fábrica
- Modelo del fabricante
- Tipo de máscara
- NR de no reutilizable
- Certificado CE
- Normativa que cumple



CAJA MASTER

CAJA MASTER DE 40*60*50 CM

1MASCARILLA/BLISTER 10MASCARILLAS/CAJA 116 CAJAS DE 10UDS / CAJA MASTER





MASCARILLA FILTRANTE FFP2 NR - TAMAÑO ADULTO

https://ec.europa.eu/growth/tools-databases/nando/index.cfm?fuseaction=notifiedbody.notifiedbody&refecd=NANDO

Notification Found: 1

Body:

MNA LABORATUVARLARI SANAYI TICARET LIMITED ŞIRKETI

KüçükbakkalköyMah. Yenidoğan Cad. No: 21

Ataşehir/İSTANBUL Country : Turkey

Phone: 00902165740708 Fax: 00902165751331

Email: info@mnalab.com

Website: https://www.mnalab.com

Notified Body number: 2841

Last approval date: 22/11/2019

Legislations

Regulation (EU) 2016/425 Personal protective equipment
 HTML PDF





DOCUMENTACIÓN Y CERTIFICADOS









TRN MedTex

www.trnmedtex.com

CE DECLARATION OF CONFORMITY

This declaration of conformity, which is the sole responsibility of the manufacturer

Producer: TRN Moda Tekstil San. Ve Tic. Ltd. Şti.

Address: Selahaddin Eyyubi Mah, 1538. Sk. No: 32/4, 34517 Esenyurt / İstanbul / Turkey

has been issued, relates to the following personal protective equipment (PPE)

Brand: TRN MedTex

Product model: TRNMT-NRF M002

Performance class: FFP2 NR

Product description: Particle Filtering Half Mask complies with the provisions of the following European regulations and / or directives Ordinance on Personal Protective

Equipment (PPE)

The model complies with the provisions of Regulation (EU) 2016/425, including compliance with applicable basic health and safety requirements according to Annex II, and the national norm for the implementation of the harmonized European standard norm (s): **EN 149: 2001 + A1: 2009** and is identical to the PPE, which is the subject of the EU type examination (Module B of Regulation [EU] 2016/425), which is referred to in the certificate number:

200-21-02

Issued by

MNA LABORATUVARLARI SAN. TİC. LTD. ŞTİ.

Küçükbakkalköy, Yenidoğan Cd. No:21, 34750 Ataşehir/İstanbul TÜRKİYE is subject to the procedures of Module C2 of Regulation (EU) 2016/425 under Supervision of Universal, notified body number 2841

Signed by: Fahri TURAN

President

Date: March 27, 2021





AB Tip İnceleme Sertifikası EU Type-Examination Certificate

Belge No / Certificate No : 200-21-02-R01

Belgelendirme Tarihi - Bir Sonraki Belge Tarihi /

Certification Date / Certificate Validity Date : 07.04.2021-29.03.2026

Belge Geçerlilik Tarihi / Document Validity Period: 5 yıl / 5 years

Firma Unvanı ve Adresi /

Company Name and Address : TRN MODA TEKSTIL SAN. VE TIC. LTD. ŞTİ.

Selahaddin Eyyubi Mah. 1538. Sk. No: 32 İç Kapı

No: 4 Esenyurt/ İSTANBUL

Ürün Adı/Modeller / Product Name / Models

Direktifi / Directive

Modülü/Kategori / Module / Category

: TRNMT-NRF M002

: 2016/425 REGULATION

: B MODÜLÜ/ KATEGORİ III MODULE B / CATEGORY III

: M-2021-00461, M-2021-00620

Test Rapor No/ları / Test Report No

Ürün Tipi / Product Type:

 EN 149:2001+ A1:2009 Solunumla ilgili koruyucu cihazlar - Parçacıklara karşı koruma amaçlı filtreli yarım maskeler/ Respiratory protective devices - Filtering half masks to protect against particles

Ürünün Malzeme Bilgisi / Product Material Information: TRNMT-NRF M002 model ürünleri kumaş, elastik kayış, burun klipsi ve filtre katmanı kullanılarak imal edilmiştir./ TRNMT-NRF M002 model products are manufactured using fabric, elastic strap, nose clip, filter layer.

Revizyon nedeni/ Reason for revision: Farklı renkte ürün eklenmiştir/ Different color product has been added.

Volkan AKIN 07.04.2021 Karar Verici / Approver Okan AKEL 07.04.2021 Şirket Müdürü / General manager



MNA Laboratuvarları San. Tic.Ltd .Şti

Adres: Küçükbakkalköy Mahallesi Yenidoğan Cad.No:21 Ataşehir/ İstanbul

Tel: 0216 574 07 08 Faks: 0216 575 13 31 www.mnalab.com




ATTACHMENTS (200-21-02-R01)

To certify the PPE product at Category III level, C2 or D module is accompanied by applying one of the conformity assessment methods along with the EU Type Examination (Module B).

Model: TRNMT-NRF M002

PPE SPECIFICATION	PERFORMANCE LEVELS
Classification	FFP2
Reusable / Single Shift Use	NR


PPE produced as a single unit to fit an individual user, all the necessary instructions for manufacturing such PPE on the basis of the approved basic model:



MNA LABORATORIES SAN. TIC. LTD. \$TI declares that the above-mentioned product meets the requirements of the directive according to the EU Directive 2016/425, the safety of the product is covered by the conditions and use specified in this certificate and in the technical file.



ATTACHMENTS (200-21-02-R01)



DOCUMENTS IN THE TECHNICAL FILE

- Basic Health Safety Requirements
- Risk Assessment
- Test Reports
- Technical Report



TECHNICAL EVALUATION REPORT (200-21-02-R01)

Report No

:200-21-02-R01

Report Date

:07.04.2021

Application No

:200-21-02

1. COMPANY INFORMATION:

TRN MODA TEKSTİL SAN. VE TİC. LTD. ŞTİ.

Selahaddin Eyyubi Mah. 1538. Sk. No: 32 İç Kapı No: 4 Esenyurt/ İSTANBUL


2. PPE INFORMATION:

Disposable and non-sterile half mask made of particulate protection fitler material.

3. PPE TYPE IDENTIFICATION

EN 149:2001+A1:2009 Respiratory protective devices – Filtering half masks to protect against particles - Requirements, testing, marking

4. PPE PICTURES



TRNMT-NRF M002



TECHNICAL EVALUATION REPORT (200-21-02-R01)

5. PPE DIMENSIONS:

TRNMT-NRF M002 model has been found to be produced using standart sizes.

6. PPE PRODUCT MATERIAL INFORMATION:

The product is made of elastic strap, nonwoven fabric on the outer and inner layers and fitler material on the middle layer.

7. ESSENTIAL HEALTH AND SAFETY REQUIREMENTS

- A visual inspection was made according to EN 149:2001 +A1:2009 for ergonomics.
- Protection levels and degrees are defined by the manufacturer.
- Suitable construction materials were determined by visual inspection according to EN 149:2001 +A1:2009.

8. ANALYSIS AND EVALUATIONS:

EN 149:2001 +A1:2009

TESTS PARAMETER		PERFO LEVELS	RMANO	Œ	RESULTS	PERFORMANCE LEVELS	EVALUATION
		FFP1	FFP2	FFP3			
Banned Azo Dyes	< 30 mg/kg			< 5 mg/kg	-	PASS	
Part 7.3 Visual inspection		Shall also the marking and the information supplied by the manufacturer			Appropriate	-	PASS
Part 7.4 Packaging	for sale packaged in are protected agains	cle filtering half mask shall be offered sale packaged in such a way that they protected against mechanical damage contamination before use.			Appropriate	-	PASS
Part 7.5 Material	When conditioned in 8.3.2 the particle filt collapse.				Appropriate	-	PASS
Part 7.6 Cleaning and disinfecting	particle filtering half	After cleaning and disinfecting the re-usable particle filtering half mask shall satisfy the penetration requirement of the relevant			Not applicable	-	Not applicable
Part 7.7 Practical performance		o negative comments should be made by ne test subject regarding any of the criteria valuated.			Appropriate	-	PASS
Part 7.8 Finish of parts		of the device likely to come into t with the wearer shall have no sharp			Appropriate	-	PASS

TESTS PARAMETER	PARAMETER	0.14 0.050,000,000	PERFORMANCE LEVELS		RESULTS	PERFORMANCE LEVELS	EVALUATION
	FFP1	FFP2	FFP3				
Part 7.9.1 Total inward leakage	At least 46 out of the 50 individual exercise result	<25	<11	<5	See the table below	FFP2	PASS
	At least 8 out of the 10 individual wearer arithmetic means	<22	<8	<2	See the table below	FFP2	PASS



TECHNICAL EVALUATION REPORT (200-21-02-R01)

	Total Inward Leakage (%)										
	Exercise 1	Exercise 2	Exercise 3	Exercise 4	Exercise 5	Average					
Subject 1 (As recieved)	7.0	6.9	7.9	8.1	8.2	7.6					
Subject 2 (As recieved)	7.2	7.8	5.2	8.3	8.1	7.3					
Subject 3 (As recieved)	7.3	8.8	7.9	7.5	7.9	7.9					
Subject 4 (As recieved)	7.0	6.1	8.8	8.1	8.1	7.6					
Subject 5 (As recieved)	6.7	6.5	9.0	9.4	8.1	7.9					
Subject 6 (After temperature conditioning)	6.6	7.3	7.1	6.6	8.1	7.1					
Subject 7 (After temperature conditioning)	6.4	7.6	7.0	7.9	10.5	7.9					
Subject 8 (After temperature conditioning)	9.1	8.0	6.5	8.1	8.0	7.9					
Subject 9 (After temperature conditioning)	6.7	6.9	6.6	7.9	6.5	6.9					
Subject 10 (After temperature conditioning)	6.8	7.9	8.1	7.9	6.7	7.5					

Subject facial dimensions

Subject	Face Length (mm)	Face Width (mm)	Face Depth (mm)	Mouth Width (mm)
1	133	132	132	65
2	125	144	116	67
3	126	135	124	75
4	123	133	134	74
5	117	135	122	73
6	122	142	133	66
7	113	132	114	75
8	135	123	123	65
9	122	135	133	74
10	135	142	125	83

TESTS PARAMETER	ARAMETER PERFORMANCE LEVELS		RESULTS	PERFORMANCE LEVELS	EVALUATION		
		FFP1	FFP2	FFP3			
Part 7.9.2 Penetration of filter	Sodium chloride, 95 L/min %, max	% 20	% 6	% 1	See the table below	FFP2	PASS
material	Paraffin oil, 95 L/min %, max	% 20	% 6	%1	See the table below	FFP2	PASS

Penetration of filter material	Sodium Chloride (%)	Paraffin Oil (%)
As recieved	4.1	4.2
As recieved	3.9	4.3
As recieved	4.1	4.2
After the simulated wearing treatment	4.2	4.6
After the simulated wearing treatment	4.3	4.9
After the simulated wearing treatment	4.3	4.8
Mechanical strength and temperature conditioning	5.5	5.6
Mechanical strength and temperature conditioning	5.3	5.4
Mechanical strength and temperature conditioning	5.4	5.6

MNA LABORATUVARLARI SAN. TİC. LTD. ŞTİ.

MNA LABORATUVARLARI

TECHNICAL EVALUATION REPORT (200-21-02-R01)

TESTS	PARAMETER	PERFO	RMANO	E LEVELS	RESULTS	PERFORMANCE	EVALUATION
	FFP1 FFP2 FFP3			LEVELS	and the second section of the House of Second section (1999).		
Part 7.10 Materials shall not be known to be likely to cause irritation or any other adverse effect to with skin health			Appropriate	-	PASS		
Part 7.11 Flammibility	Mask shall not burn or not to continue to burn for more than 5 s			Flame not seen	-	PASS	
Part 7.12 Carbondioxide content of the inhalation air	Shall not exceed an a	average o	f % 1		0,81 0,84 0,79	-	PASS
Part 7.13 Head harness	It can be donned and	d removed	deasily		Appropriate	-	PASS
Part 7.14 Field of vision	The field of vision sh performance test.	nall accep	table in	practical	Appropriate	-	PASS
Part 7.15 Exhalation valve(s)	It shall withstand axially a tensile force of 10 N apply for 10 s. If fitted, shall continue to operate correctly after a continuous exhalation flow of 300 L/min over a period of 30 s.			Not applicable	-	Not applicable	

TESTS PARAMETER	PARAMETER	PERFORMANCE LEVELS			RESULTS	PERFORMANCE	EVALUATION
		FFP1	FFP2	FFP3		LEVELS	
Part 7.16 Breathing	Inhalation 30L/min	0,6 mbar	0,7 mbar	1,0 mbar	See the table below	FFP2	PASS
Resistance	Inhalation 95L/min	2,1 mbar	2,4 mbar	3,0 mbar	See the table below	FFP2	PASS
	Exhalation 160L/min	3,0 mbar	3,0 mbar	3,0 mbar	See the table below	FFP2	PASS

Breathing Resistance (mbar)	Inhalation 30L/min	Inhalation 95L/min
As recieved	0.5	1,9
As recieved	0.5	1,8
As recieved	0.5	1,9
After temperature conditioning	0.5	1,9
After temperature conditioning	0.5	1,9
After temperature conditioning	0.5	1,8
After the simulated wearing treatment	0.4	1,9
After the simulated wearing treatment	0.5	1,8
After the simulated wearing treatment	0.5	1,8

Breathing Resistance 160L/min (mbar)	Facing directly ahead	Facing vertically upwards	Facing vertically downwards	Lying on the left side	Lying on the right side
As recieved	2,2	2,2	2,2	2,1	2,2
As recieved	2,2	2,2	2,2	2,1	2,2
As recieved	2,2	2,2	2,2	2,2	2,2
After temperature conditioning	2,1	2,2	2,2	2,2	2,2



TECHNICAL EVALUATION REPORT (200-21-02-R01)

After temperature conditioning	2,1	2,2	2,2	2,2	2,2
After temperature conditioning	2,1	2,2	2,1	2,2	2,2
After the simulated wearing treatment	2,2	2,2	2,2	2,2	2,2
After the simulated wearing treatment	2,2	2,2	2,2	2,2	2,2
After the simulated wearing treatment	2,2	2,2	2,2	2,2	2,2

TESTS	PARAMETER	PERFO	RMANO S	CE	RESULTS	PERFORMANCE LEVELS	EVALUATION
		FFP1	FFP2	FFP3			
Part 7.17 Clogging	After clogging the inhalation resistances shall not exceed. (valved)	4 mbar	5 mbar	7 mbar	Not applicable	-	Not applicable
	The exhalation resistance shall not exceed 3 mbar at 160 L/ min continuous flow (valved)				Not applicable	-	Not applicable
	After clogging the inhalation and exhalation resistances shall not exceed. (valveless)	3 mbar	4 mbar	5 mbar	Not applicable	-	Not applicable
Part 7.18 Demountable part	All demountable par readily connected possible by hand.				Not applicable	-	Not applicable

9. DECISION PROPOSAL

Analysis and examinations TRNMT-NRF M002 model coded personal protective equipment; Respiratory Protective Devices EN 149:2001 +A1:2009- Filtered Half Masks for Protection Against Particles - Properties, Experiments and Marking standards are evaluated. It is recommended to be certified at the performance levels specified as a result of technical evaluations.

10. ATTACHMENTS

- Basic Health Safety Requirements
- Risk Assessment
- User Instruction

Reason for revision : Different color product has been added.

CONTROLLER : VOLKAN AKIN

SING

DATE



CONFORMITY TO TYPE BASED ON INTERNAL PRODUCTON CONTROL PLUS SUPERVISED PRODUCT CHECK AT RANDOM INTERVALS

(MODULE C2, ANNEX VII) (200-21-02-R01-01)

Report No : 200-21-02-R01-01

Report Date : 08.04.2021

Application No : 200-21-02-R01-01

1. COMPANY INFORMATION:

TRN MODA TEKSTİL SAN. VE TİC. LTD. ŞTİ.

Selahaddin Eyyubi Mah. 1538. Sk. No: 32 İç Kapı No: 4 Esenyurt/İSTANBUL


2. PPE INFORMATION:

Disposable and non-sterile half mask made of particulate protection fitler material.

3. PPE TYPE IDENTIFICATION

EN 149:2001+A1:2009 Respiratory protective devices – Filtering half masks to protect against particles - Requirements, testing, marking

4. PPE PICTURES



TRNMT-NRF M002



CONFORMITY TO TYPE BASED ON INTERNAL PRODUCTON CONTROL PLUS SUPERVISED PRODUCT CHECK AT RANDOM INTERVALS (MODULE C2, ANNEX VII) (200-21-02-R01-01)

5. PPE DIMENSIONS:

TRNMT-NRF M002 model has been found to be produced using standard sizes.

6. PPE PRODUCT MATERIAL INFORMATION:

The mask is made of elastic strap, nonwoven fabric on the outer and inner layers and fitler material on the middle layer.

7. ESSENTIAL HEALTH AND SAFETY REQUIREMENTS

- A visual inspection was made according to EN 149:2001 +A1:2009 for ergonomics.
- · Protection levels and degrees are defined by the manufacturer.
- Suitable construction materials were determined by visual inspection according to EN 149:2001 +A1:2009.

8. ANALYSIS AND EVALUATIONS:

EN 149:2001 +A1:2009

TESTS	PARAMETER	PERFO LEVELS	RMANO	Œ	RESULTS	PERFORMANCE LEVELS	EVALUATION	
		FFP1	FFP2	FFP3				
Banned Azo Dyes	< 30 mg/kg	g/kg				-	PASS	
Part 7.3 Visual inspection	Shall also the marking and the information supplied by the manufacturer			Appropriate	-	PASS		
Part 7.4 Packaging	Particle filtering half mask shall be offered for sale packaged in such a way that they are protected against mechanical damage and contamination before use.				Appropriate	-	PASS	
Part 7.5 Material	When conditioned in accordance 8.3.1 & 8.3.2 the particle filter half mask shall not collapse.				Appropriate	-	PASS	
Part 7.6 Cleaning and disinfecting	After cleaning and disinfecting the re-usable particle filtering half mask shall satisfy the penetration requirement of the relevant class.			sfy the	Not applicable	-	Not applicable	
Part 7.7 Practical performance	No negative comments should be made by the test subject regarding any of the criteria evaluated.				Appropriate	-	PASS	
Part 7.8 Finish of parts	Parts of the device likely to come into contact with the wearer shall have no sharp edge or burrs.				Appropriate	-	PASS	



CONFORMITY TO TYPE BASED ON INTERNAL PRODUCTON CONTROL PLUS SUPERVISED PRODUCT

CHECK AT RANDOM INTERVALS

(MODULE C2, ANNEX VII) (200-21-02-R01-01)

TESTS	PARAMETER PERFORMANCE LEVELS		RESULTS	PERFORMANCE LEVELS	EVALUATION		
	FFP1 FFP2 FFP3						
Part 7.9.1 Total inward leakage	At least 46 out of the 50 individual exercise result	<25	<11	<5	See the table below	FFP2	PASS
	At least 8 out of the 10 individual wearer arithmetic means	<22	<8	<2	See the table below	FFP2	PASS

Total Inward Leakage (%)									
	Exercise 1	Exercise 2	Exercise 3	Exercise 4	Exercise 5	Average			
Subject 1 (As recieved)	7.3	8.5	7.9	8.4	6.7	7.8			
Subject 2 (As recieved)	7.9	5.5	6.0	6.7	6.6	6.5			
Subject 3 (As recieved)	7.6	8.8	7.3	8.5	7.9	8.0			
Subject 4 (As recieved)	7.5	8.2	8.0	8.5	8.8	8.2			
Subject 5 (As recieved)	7.3	8.5	7.9	5.6	7.4	7.3			
Subject 6 (After temperature conditioning)	7.6	7.9	6.1	6.7	8.9	7.4			
Subject 7 (After temperature conditioning)	7.3	7.3	8.5	7.9	7.4	7.7			
Subject 8 (After temperature conditioning)	7.3	8.5	7.9	7.9	7.6	7.8			
Subject 9 (After temperature conditioning)	8.5	7.9	6.1	8.4	7.9	7.8			
Subject 10 (After temperature conditioning)	6.1	8.4	5.6	7.4	8.4	7.2			

Subject facial dimensions

Subject	Face Length (mm)	Face Width (mm)	Face Depth (mm)	Mouth Width (mm)	
1	133	132	132	65	
2	125	144	116	67	
3	126	135	124	75	
4	123	133	134	74	
5	117	135	122	73	
6	122	142	133	66	
7	113	132	114	75	
8	135	123	123	65	
9	122	135	133	74	
10	135	142	125	83	

TESTS PARAMETER	PARAMETER	PERFORMANCE LEVELS		RESULTS	PERFORMANCE LEVELS	EVALUATION	
		FFP1	FFP2	FFP3			
Part 7.9.2 Penetration of filter	Sodium chloride, 95 L/min %, max	% 20	% 6	% 1	See the table below	FFP2	PASS
material	Paraffin oil, 95 L/min %, max	% 20	% 6	%1	See the table below	FFP2	PASS



CONFORMITY TO TYPE BASED ON INTERNAL PRODUCTON CONTROL PLUS SUPERVISED PRODUCT

CHECK AT RANDOM INTERVALS (MODULE C2, ANNEX VII) (200-21-02-R01-01)

Penetration of filter material	Sodium Chloride (%)	Paraffin Oil (%)
As recieved	3.9	4.2
As recieved	4.2	4.5
As recieved	4.2	4.4
After the simulated wearing treatment	4.2	4.4
After the simulated wearing treatment	4.1	4.6
After the simulated wearing treatment	4.2	4.5
Mechanical strength and temperature conditioning	5.7	5.2
Mechanical strength and temperature conditioning	5.5	5.8
Mechanical strength and temperature conditioning	5.3	5.5

TESTS	PARAMETER	PERFO	RMANO	E LEVELS	RESULTS	PERFORMANCE	EVALUATION
		FFP1	FFP2	FFP3		LEVELS	
Part 7.10 Compatibility with skin	Materials shall not cause irritation or ar health			8 100000000000 CONSCRI	Appropriate	-	PASS
Part 7.11 Flammibility	Mask shall not burn of for more than 5 s	or not to	continu	e to burn	Flame not seen	-	PASS
Part 7.12 Carbondioxide content of the inhalation air	Shall not exceed an a	verage o	f % 1		0,88 0,84 0,83	-	PASS
Part 7.13 Head harness	It can be donned and	remove	deasily		Appropriate	-	PASS
Part 7.14 Field of vision	The field of vision sh performance test.	all accep	table in	practical	Appropriate	-	PASS
Part 7.15 Exhalation valve(s)	It shall withstand axis apply for 10 s. If fitted, shall continuous after a continuous L/min over a period of	nue to c	perate	correctly	Not applicable	1	Not applicable

TESTS F	PARAMETER	PERFO	RMANO	E LEVELS	RESULTS	PERFORMANCE	EVALUATION
		FFP1	FFP2	FFP3		LEVELS	
Part 7.16 Breathing	Inhalation 30L/min	0,6 mbar	0,7 mbar	1,0 mbar	See the table below	FFP2	PASS
Resistance Inhalation 95L/m	Inhalation 95L/min	2,1 mbar	2,4 mbar	3,0 mbar	See the table below	FFP2	PASS
	Exhalation 160L/min	3,0 mbar	3,0 mbar	3,0 mbar	See the table below	FFP2	PASS



CONFORMITY TO TYPE BASED ON INTERNAL PRODUCTON CONTROL PLUS SUPERVISED PRODUCT

CHECK AT RANDOM INTERVALS

(MODULE C2, ANNEX VII) (200-21-02-R01-01)

reathing Resistance (mbar)	Inhalation 30L/min	Inhalation 95L/min
As recieved	0,6	2,2
As recieved	0,6	2,2
As recieved	0,5	2,3
After temperature conditioning	0,5	2,3
After temperature conditioning	0,6	2,3
After temperature conditioning	0,5	2,2
After the simulated wearing treatment	0,5	2,3
After the simulated wearing treatment	0,6	2,3
After the simulated wearing treatment	0,6	2,3

Breathing Resistance 160L/min (mbar)	Facing directly ahead	Facing vertically upwards	Facing vertically downwards	Lying on the left side	Lying on the right side
As recieved	2,8	2,8	2,8	2,7	2,8
As recieved	2,7	2,8	2,8	2,7	2,8
As recieved	2,7	2,8	2,8	2,7	2,8
After temperature conditioning	2,7	2,8	2,8	2,8	2,8
After temperature conditioning	2,8	2,8	2,8	2,8	2,8
After temperature conditioning	2,8	2,8	2,8	2,8	2,8
After the simulated wearing treatment	2,8	2,8	2,7	2,8	2,8
After the simulated wearing treatment	2,8	2,8	2,7	2,8	2,8
After the simulated wearing treatment	2,8	2,8	2,8	2,8	2,8

TESTS	PARAMETER	PERFC LEVEL	RMAN(S	CE	RESULTS	PERFORMANCE LEVELS	EVALUATION
		FFP1	FFP2	FFP3			
Part 7.17 Clogging	After clogging the inhalation resistances shall not exceed. (valved)	4 mbar	5 mbar	7 mbar	Not applicable	-	Not applicable
	The exhalation resist 3 mbar at 160 L/ (valved)				Not applicable	-	Not applicable
	After clogging the inhalation and exhalation resistances shall not exceed. (valveless)	3 mbar	4 mbar	5 mbar	Not applicable	-	Not applicable
Part 7.18 Demountable part	All demountable par readily connected possible by hand.				Not applicable		Not applicable



CONFORMITY TO TYPE BASED ON INTERNAL PRODUCTON CONTROL PLUS SUPERVISED PRODUCT CHECK AT RANDOM INTERVALS (MODULE C2, ANNEX VII) (200-21-02-R01-01)

9. DECISION

Analysis and examinations TRNMT-NRF M002 model coded personal protective equipment; Respiratory Protective Devices EN 149:2001 +A1:2009- Filtered Half Masks for Protection Against Particles - Properties, Experiments and Marking standards are evaluated. The homogeneity of the production was monitored at the performance levels determined as a result of the technical evaluations made within the scope of MODULE C2.

10. ATTACHMENTS

- **Basic Health Safety Requirements**
- Risk Assessment
- Test Reports (M-2021-00621, M-2021-00620)
- **User Instruction**

CONTROLLER

: VOLKAN AKIN

SING

DATE